

Company: UNICRIMP Limited
Declares that under our sole responsibility the product(s)

Product Name: Q-Fire Products & Components

Description: Cable Clips - Fire Safe Cable Clips

Product Reference(s): QFGFC25, QFGFC40 & QFGFC50

is/are in conformity with the provisions of the following statutory requirements, including all amendments, and with national legislation implementing these regulations:

UK SI 2012 No. 3032 *Restriction of the use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations*

UK SI 2021 No. 904 *Registration, Evaluation, Authorisation and Restriction of Chemicals 2021 (REACH)*

UK SI 2013 No. 3113 *UK Packaging Waste Regulations*

The following designated standards have been applied:

BS 5839-1:2013 (Section 26.2e) *Fire detection and fire alarm systems for buildings – Part 1: Code of practice for design, installation, commissioning and maintenance of systems in non-domestic premises*

BS 8434-2 :2003 *Methods of test for assessment of the fire integrity of electric cables-Part 2: Test for unprotected small cables for use in emergency circuits- BS EN 50200 with a 930 °C flame and with water spray*

BS EN 50200:2006 PH120 *Method of test for resistance to fire of unprotected small cables for use in emergency circuits*

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001: 2015.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of:
Unicrimp Limited.



Karl Rawlins - Technical Author

Date: 4 August 2022

Place of Issue: As Below

Company: UNICRIMP Limited
Declares that under our sole responsibility the product(s)

Product Name: Q-Fire Products & Components

Description: Cable Clips - Fire Safe Cable Clips

Product Reference(s): QFGFC25, QFGFC40 & QFGFC50

are / is in conformity with the provisions of the following EU directives and regulations, including all amendments, and with national legislation implementing these directives:

2011/65/EU & 2015/863/EU *Restriction of the use of Certain Hazardous Substances in Electrical and Electronic Equipment Directives*

1907/2006/EU *European Regulation on Registration, Evaluation, Authorisation and Restriction of Chemicals*

94/62/EC *European Directive on Packaging and Packaging Waste*

The following designated standards have been applied:

BS 5839-1:2013 (Section 26.2e) *Fire detection and fire alarm systems for buildings – Part 1: Code of practice for design, installation, commissioning and maintenance of systems in non-domestic premises*

BS 8434-2 :2003 *Methods of test for assessment of the fire integrity of electric cables-Part 2: Test for unprotected small cables for use in emergency circuits- BS EN 50200 with a 930 °C flame and with water spray*

BS EN 50200:2006 PH120 *Method of test for resistance to fire of unprotected small cables for use in emergency circuits*

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001: 2015.

This declaration has been issued under the sole responsibility of the manufacturer, signed at, for and on behalf of: Unicrimp Limited.



Karl Rawlins - Technical Author
Date: 4 August 2022
Place of Issue: As Below

CE