





## Emergency Lighting Spacing Table

### Luminaire Spacing (Centre to centre in metres) on emergency escape routes

Mounting height	Lux level directly beneath	Transverse distance to wall for level of illuminance (lux)			Transverse to transverse spacing for level of illuminance (lux)			Transverse to axial spacing for level of illuminance (lux)			Axial to axial spacing for level of illuminance (lux)			Axial distance to wall for level of illuminance (lux)			Spacing (m) in Anti - Panic Open Areas of 0.5 lux minimum (inc 0.5 border area)			
		0.2	0.5	1.0	0.2	0.5	1.0	0.2	0.5	1.0	0.2	0.5	1.0	0.2	0.5	1.0				
<b>Glade 1W</b>																				
2.5m	5.2 lux	3.9	3.0	2.4	8.5	6.4	5.2	8.5	6.4	5.2	8.5	6.4	5.2	3.9	3.0	2.4	3.2	6.5	6.5	3.2
4m	2.03 lux	4.9	3.4	2.2	10.6	7.8	6.0	10.6	7.8	6.0	10.6	7.8	6.0	4.9	3.4	2.2	3.5	7.6	7.6	3.5
<b>Glade 5W</b>																				
2.5m	66.89 lux	4.6	3.4	2.8	9.9	7.3	5.7	9.9	7.3	5.7	9.9	7.3	5.7	4.6	3.4	2.8	2.7	6.0	6.0	2.7
4m	26.1 lux	5.2	4.0	3.4	12.2	8.5	7.3	12.2	8.5	7.3	12.2	8.5	7.3	5.2	4.0	3.4	2.9	7.3	7.3	2.9
6m	11.6 lux	6.25	4.6	3.9	14.7	10.5	9.6	14.7	10.5	9.6	14.7	10.5	9.6	6.25	4.6	3.9	3.8	8.9	8.9	3.8
8m	6.53 lux	6.9	5.25	4.2	15.0	11.9	9.7	15.0	11.9	9.7	15.0	11.9	9.7	6.9	5.25	4.2	3.6	10.9	10.9	3.6

*Illuminance values based on maintenance factor of 0.9*