


www.hamilton-litestat.com



I R312 SS-B

Grid Fix Insert Rocker Intermediate 20AX Satin Steel/Black. Standard Insert will be Satin Steel with a Black surround.

| Primary Range | GRID-IT | |
|---------------------------|------------------------------|--|
| Insert Type | Intermediate Rocker Switches | |
| Plate Finish | | |
| Frame Finish | | |
| Switch Colour | Satin Steel | |
| Body & Switch Trim | Black | |
| Height | | |
| Width | | |
| Depth | | |
| Fixing Hole Centres | | |
| Minimum Wall Box Depth | 35mm | |
| Wattage | | |
| Switched Poles | Double | |
| Current Rating | 20AX | |
| Voltage | 220/250V AC | |
| Max load | 20 Amp inductive | |
| Contact Gap Minimum | 3mm | |
| Terminal Capacity 1 | 5 x 1mm2 | |
| Terminal Capacity 2 | 4 x 1.5mm2 | |
| Terminal Capacity 3 | 2 x 2.5mm2 | |
| Terminal Capacity 4 | 2 x 4mm2 Multi-Strand | |
| Terminal Capacity 5 | 1 x 6mm2 | |
| Earth Terminal Capacity 1 | 6 x 1mm2 | |
| Earth Terminal Capacity 2 | 5 x 1.5mm2 | |
| Earth Terminal Capacity 3 | 3 x 2.5mm2 | |
| Earth Terminal Capacity 4 | 2 x 4mm2 Multi-Strand | |
| Earth Terminal Capacity 5 | 1 x 6mm2 | |
| Product Class 1 | Face plate must be earthed | |
| Ambient Operating | -5° to +40°C | |
| Temperature | -5 t0 +40 C | |
| Recommended Location | Indoor use only | |
| Standard/Approval | BS EN 60669-1 | |
| Patents and Trademarks | | |

| All products listed conform to current British or European standards and the product information is correct at the time of going to press. | All accessories are manufactured under an accredited BS EN ISO 9001 : 2008 Quality System. | It is the policy of the company to continually improve products as part of our development programme. Therefore, we reserve the right to alter designs and dimensions without prior notice. |
|--|--|--|
| Illustrations and diagrams are reproduced within the limitations of reproductions and printing processes are not binding. | Due to manufacturing processes we cannot guarantee an exact colour match and shadings of certain finishes. | Correct as at August 2012 E&OE |

R Hamilton & Co Ltd • Quarry Industrial Estate • Mere • Wiltshire • BA12 6LA • UK T: +44 (0)1747 860088 • F: +44 (0)1747 861032 • E: info@hamilton-litestat.com www.hamilton-litestat.com

Directors: R Hamilton • I Hamilton • RL Haines • CP Savory • AMH Hamilton (Secretary)
Registered Office: Cedar House • Breckland • Linford Wood • Milton Keynes • MK14 6EX • Buckinghamshire
Registered in London No. 941624 • VAT Registration No. 222 6607 84







